



THOMAS POUR
Fire Chief
tpour@belleville.net

BELLEVILLE FIRE DEPARTMENT

1125 South Illinois Street
Belleville, IL 62220
Phone (618) 234-2236
Fax (618) 277-0105

ARTHUR JACOBS
Deputy Fire Chief / Training
ajacobs@belleville.net



J. P. PENET
Ass't Fire Chief / Fire Prevention
jpenet@belleville.net

Belleville Fire Department Regulations for the Downtown Events

- Each vendor with an open flame is required to have a fire extinguisher at their booth for emergencies, a minimum of a **3A40BC** fire extinguisher (10 lb). In **addition**, for vendors who deep fry, the Belleville Fire Department requires a “**K**” fire extinguisher for oils and greases.
- No Generators allowed.
- Electric is provided by City, vendors must use 12 gauge or larger extension cord, 50-foot in length. Vendors must have a separate extension cord for each circuit, to not overload the cord rating. If rain is forecast, keep all extension cords out of the gutters and standing water.
- All propane tanks must be secured. The smaller 20 lb tanks can be in a milk crate, but larger tanks need to be secured with a light weight chain to a secure post or wall.
- All vendors **MUST** allow 48 inch width clear sidewalk for ADA compliance. Watch for trip hazards around your stand.
- All tents must be secured at legs and appropriately weighted.
- These regulations are for the safety of your customers, and for yourself.

6/12/2017